


Certificate of Appropriateness

The Loudoun County Historic District Review Committee hereby approves this Certificate of Appropriateness (2011-0016), issued to David and Lisa Marvil for the parcel identified as MCPI# 492-36-1990 in the Goose Creek Historic and Cultural Conservation District on September 12, 2011 for the construction of a new single family dwelling. The application was approved with the following conditions:

1. That the window dimensions are consistent with the drawings except the master bathroom window on the rear elevation which will be consistent with all other 2nd floor windows on the rear elevation;
2. That the foundation is parged or veneered in stone or brick;
3. That the standing seam metal roof will have no more than 1 ½ inch seams and a panel width of 17 inches;
4. That the French doors on all elevations will have eight simulated divided lights and the windows will be four-over-four (still with simulated divided lights).



Vice Chairman, Historic District Review Committee

10/17/11

Date





Zoning Administrator

10/20/11

Date

I understand that, to avoid a possible violation of the Zoning Ordinance, I must return to the Historic District Review Committee if any changes are made to the approved plans:





Applicant

9/19/11

Date